


MIDWEST PARAGON™ MVAV SERIES VACUPAC™ AERVENT


DETAILS ARE SUBJECT TO CHANGE WITHOUT PRIOR NOTICE.
CAUTION: EXPLOSION PROOF CONSTRUCTION AVAILABLE.
CONSULT FACTORY FOR DETAILS AND PRICING



FAN POSITIONS
POSITION (1) STANDARD
(SPECIFY IF OTHER
THAN STANDARD)


CLEAN AIR FAN WITH
CAST ALLOY HOUSING
AND BIRD SCREEN

FILTER HOUSING 11GA.
(SPECIFY CLASS OF CONSTRUCTION)
CLASS IA, STANDARD
CLASS IIA AND IV AVAILABLE





HINGED SEALMASTER™ FILTER
INSPECTION DOOR WITH 1" 7/8" RING SEAL


MODEL	CFM	A/C RATIO
MABV234	350	2.7:1
MABV234	500	2.7:1
MABV234	700	2.9:1




SEALMASTER™ CAST ALUMINUM
CLEAN AIR PLENUM INSPECTION
DOOR 8" DIAMETER WITH
CAMILLOC™ RELEASE HANDLE



(3) 12.75 [323.9] DIA FILTERS
26.00 [660.4] LONG FOR
234 SQ-FT MEDIA



PURGE CONTROLLER ENCLOSURE NEMA 4 (16 X 12 X 6)
(406mm X 305mm X 152mm) SOLID STATE PULSE CONTROL
AND FILTER VACUUM GAUGE CONTINUOUS CLEAN, PHOTOHELIC
PRESSURE DIFFERENTIAL WITH DIGITAL DISPLAY AND 4-20mA
ANLOG OUTPUT INCLUDED.



Operational Headquarters
Midwest Plaza, 105 Slower Rd.
Charlevoix, Michigan 49720
Phone (231) 547-4000
Fax (231) 547-9453
a division of
ron pair enterprises, inc.

REF. SERIAL NO. JOB NO. SHEET NO. DRAWING NO. MVAV234

PREPARED FOR: P.O. NO. TITLE: VACUPAC AERVENT DRAWN: BW DATE: 25 JAN 13

DATE: CHECKED: WP

This drawing and/or publication represents proprietary article and the designs, trade names or trademarks therein are either patented, have patents pending or are copyrighted internationally. Information appearing on this document remains the property of Ron Pair Enterprises, Inc. and is not to be reproduced without written authorization from an officer of this corporation.

REVISION NO. DATE: